DEQ | Drinking Water

Public Water System IPS Report

PWS ID: UTAH26012 Aspen Crest Girls Camp Rating: Approved 04/09/1996 Status: Active

Type: Administrative Contact

Name: ROY BENSON MCDANIEL Office: 801-240-4656

Emergency:

Contacts

Email: mcdanielrb@ldschurch.org

Address: 50 E NORTH TEMPLE ST,

RM 1205 NATURAL RESOURCE SERVICES, SALT LAKE CITY, UT

84150-6320

Site Information

Phone: 801-240-4656

County: WASATCH COUNTY System Type: Non-Community

Population: 600

System is required to disinfect as of

09/05/2018

Site Updates

Last Inventory Update: 06/07/2017

Last Surveyor Update: 07/25/2017

Operating Period: 6/1 - 8/31

Surveyor: TRACY RICHARDSON

Last IPS Update: 08/14/2019 15:00:00

Political Districts

Representative: 54

Senate: 26

Water Usage Information per ERC

IPS SUMMARY Total IPS Pts: 5 Admin & Physical Facilities Quality & Monitoring Significant Deficiency Violations 0 5 0

PHYSICAL FACILITY POINTS Total Pts: 5				
Code	Description	Severity	Points Effective	Details
M001	CURRENT EMERGENCY RESPONSE PROGRAM	REC	-10	View Details (1)
SS01	LACKS A PERMANENT DEVICE FOR MEASURING SPRING FLOW	MIN	5	View Details (1)
SS02	SPRING COLLECTION AREA NOT FENCED	MIN	10	View Details (1)

SIGNIFICANT DEFICIENCY VIOLATIONS Total Pts: 0 ID Violation Code Deficiency Determined Points Effective

LEAD COPPER MONITORING AND QUALITY VIOLATIONS Total Pts: 0 Description/Name Points Effective Violation No. Period Code

Date

Code

Description/Name

PUBLIC NOTIFICATION VIOLATIONS

Violation No.

Total Pts: 0

Points Effective